LABORATORY

PUBLIC HEALTH ENGINEERING DEPARTMENT

MAINTENANCE SUB DIVISION NO. 2, P.H.E. DEPTT.., UJJAIN

Sample from

I.B.S. Global Academy, Sanwer Road, Ujjain

Particular of sample

Sample No. 1) R.O. Water

Date of collection

07-02-25

Date of Analysis

07-02-25

S. No.	Characteristics	Unit	Appendix As per manual on water supply Treatment prepared published by CPHEEO- Manual		Result R.O. Water					
			Acceptable C	ause for rejection	(1)	2	3	4	5	6
	Physical									
1.	Turbidity	NTU	2.5	10.0	0.0					
2.	Colour	PICobal t	5.0	25.0	NIL					- 3
3	Taste and odour Chemical	Scale -	Unobjectionable	Unobjectionable	NIL					*
4.	PH	PH	7.0 to 8.5	<6.5 to 9.2>	7.02					
		Scale								
5.	Total Alkalinity	Mg/1	200	600	090			2		
6.	Chloride	-	Up to 200	1000	052					-
7.	Total Hardness	Mg/1	200as CaCO3	600as CaCO3	076					100
8.	Calcium Hardness	-								
9.	Magnesium Hard.	-								
10.	Total Dissolved Solids	-	500	2000	105				,	
11.	Iron	Mg/1	0.1	1.0	NIL				14.64	
12.	Fluride	-	1.0	1.5	NIL					
13.	Maganese	-	0.3	1.0	-					
14.	Dissolved oxygen	-	-	-	-					
15.	C.O.D.	-	10	_	-11					
16.	B.O.D.	-	06	<u>-</u>						
17.	Residual Chlorine	-	02	1.0	NIL	42				
18.	Coagulant dose At test	-	-	•						
									*	

Note: 1. The figure indicated under the columnaccetable are the limits upto which the water is generally Acceptable to the consumers.

2. Figure in excess to those mentioned under acceptable render the water not acceptable but still Tolerated in the absence of alternative and better source but upto the limits indicated under Column 'cause for rejection' above which the supply will have to be rejected.

Bacteriological (M.	P.N.) of coli form per 100 ml of sample – No. 1) I	NIL
Special Tests		
(1)		
(2)		
(3)		
Chemist :		
Remarks : All the to	ested parameter results are under limits as per CI	PHEEO manual.
So, wate	er can be used for the drinking purpose. 🗸	
		Mari'
		Laboratory Jacharge
		Water treatment poart & lab Gaughat FILTRAEIND RIADJAIN
		GAU GHAT, ULIAIN
Note :		
East :		
	ON INDIA COMPONIMENT SEDVICE	
	ON INDIA GOVERNMENT SERVICE	
	V10,	ST'AMP
No	IBS Global Academy	
	Sanwer Road	
	Ujjain (M.P.)	